



City of Cleveland  
Justin M. Bibb, Mayor

Department of Finance  
Division of Purchases & Supplies  
601 Lakeside Avenue, Room 128  
Cleveland, Ohio 44114-1080  
216/664-2620 • Fax: 216/664-2177  
www.cleveland-oh.gov

May 10, 2024

**ADDENDUM 1**

**BID TITLE: File No. 53-24 Transmission Corrosion Control I**

**BID DUE: Friday, May 24, 2024 at 12 o'clock noon (Eastern Time)**

**Attention Bidders:**

We have been requested to issue the addendum for the following:

Please ensure that a copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

1. Extend the bid due date.
2. Answers to questions received by the last day for questions.

If you have any questions regarding the attached, please contact Purchases and Supplies at 216-664-2620. Thank you for your prompt attention and assistance in this matter.

\_\_\_\_\_  
Signature of Potential Bidder & Name of Company

\_\_\_\_\_  
Today's Date

Thank you,

Donia Patterson, Assistant Administrator  
Purchases & Supplies

CC:

Attachments

## TRANSMISSION MAIN CORROSION CONTROL I – FILE NO. 53-24

### ADDENDUM NO. 1

**The bid due date is extended to May 24, 2024 and bids must be date stamped no later than 11:59 a.m. that day.**

#### **Answers to questions received by the last day for questions:**

1. What is the timeline for this work to start?

Answer: After Notice to Proceed the project is to be completed in 365 days.

2. Will we be supplied a "lay-down" yard or a place to send the material for the job, or will this be our responsibility?

Answer: It is the Contractor's responsibility.

3. It does not specify a casing for the deep well installation. We are expecting a water table through the layers. With that said is steel casing permitted where necessary to stabilize the drill path and control the cuttings?

Answer: Section 26 42 13-Deep Anode Cathodic Protection details the use of a PVC casing at the top of the deep well (12in diameter, 20ft length). The use of metal casings is not allowed unless otherwise authorized by the Engineer. See "2.02 Groundbed Materials, Section A Items 7&8, 3.03 Groundbed General, Sections E-G."

4. Are we able to begin the drill from soil grade?

Answer: No, Section 26 42 13-Deep Anode Cathodic Protection details vacuum excavation for the first 15ft. See "3.03 Groundbed General, Section A: Deep anode groundbeds shall be vacuum excavated for the first 15 feet, unless otherwise noted in the Contract Drawings, to ensure no underground utilities are encountered before drilling."

5. Will engineering service be needed from our in-house CP-4/Engineer for consultation or commissioning? If so, will he need to have a Ohio License (Currently PA, WI, MI, and IN).

Answer: Yes, the contractor is responsible for providing this service and it will require an Ohio license as per Section 26 42 13-Deep Anode Protection. See "1.04 Contractor Submittals, Sections C and D."

6. Lastly, is night work permitted to better manage progress without heavy traffic etc.?

Answer: The project coordinated with the municipalities under the assumption that construction would occur during specified normal working hours. The contractor will need approval from both CWD and the municipality for work to occur during non-specified hours.