



City of Cleveland
Justin M. Bibb, Mayor

Department of Finance
Division of Purchases & Supplies
601 Lakeside Avenue, Room 128
Cleveland, Ohio 44114-1080
216/664-2620 • Fax: 216/664-2177
www.cleveland-oh.gov

January 15, 2025

ADDENDUM 1

BID TITLE: File No. 146-24 Traveling Screens Improvements Re-Bid

BID DUE: Thursday, January 23, 2025 at 12 o'clock noon (Eastern Time)

Attention Bidders:

We have been requested to issue the addendum for the following:

Please ensure that a copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

1. Release the sign-in sheets from the pre-bid meeting and site visits.
2. Answer questions received.

If you have any questions regarding the attached, please contact Jules Gilliam at jjilliam@clevelandohio.gov. Thank you for your prompt attention and assistance in this matter.

Also, please ensure that copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Signature of Potential Bidder & Name of Company

Today's Date

Thank you,
Donia Patterson, Assistant Administrator
Purchases & Supplies
CC:

TRAVELING SCREENS IMPROVEMENTS RE-BID – FILE NO. 146-24

ADDENDUM NO. 1

The bid due date is January 23, 2025, and bids must be date stamped by 11:59 a.m. that day.

Release the sign-in sheets from the pre-bid meeting and site visits.

Answers to questions received by the last day for questions:

1. Please advise if program modifications for the plant wide SCADA systems are required after the new control panels are installed or if that is to be completed under a separate contract.

Answer: Section 40 61 13, paragraph 1.1.D indicates that a Control System Integrator shall update the PCCS, as part of this contract.

2. Sheet E-7 indicates to install a fiberoptic patch cord to be installed in the Potassium Permanganate control panel. Please provide a specification for the cable and connectors to be used.

Answer: DPU will provide a new network switch and SM fiberoptic patch cable which they will install in the POTP panel. Contractor is responsible for running the CAT-6 cables down to the new Traveling Screen control panels, and for the terminating and testing of the Ethernet cables and connectors.

3. It was mentioned that a traveling screen frame was in need of repair at Baldwin. Please advise on what the repairs will need to be.

Answer: The head frame, stored at Fairmount, is not square and will need to be realigned. The head frame shall be shipped to the manufacturer along with the traveling screen which is to be factory re-built. The manufacturer will then refurbish and straighten the head frame.

CITY OF CLEVELAND
DEPARTMENT OF PUBLIC UTILITIES/DIVISION OF WATER
NON-MANDATORY PRE-BID MEETING
Friday, December 27, 2024
10:00 a.m.

Traveling Screens Improvements Re-Bid

SIGN-IN SHEET

REPRESENTATIVE NAME (PLEASE PRINT)	COMPANY NAME (PLEASE PRINT)	TELEPHONE NUMBER	E-MAIL ADDRESS (PLEASE PRINT CLEARLY)
Gary Flaschberger	BissNuss	330-533-5531	gflaschberger@bissnussinc.com
Tom Kofeldt	Evoqua/Xylem	215-712-7032	thomas.kofeldt@xylem.com
Ben Griffiths	Cold Harbor	440-285-8842	beng@coldharbor.us
Jason Balint	Cold Harbor	440-285-8842	balintj@coldharbor.us
Karolyn Beals	Underwater Marine	216-883-6683	uwmarine@gmail.com
Rick Nerone	Nerone & Sons	216-662-2235	richard@nerone.biz
Scott Veley	DPU		
Craig Call	DPU		
Wendy Bruzas	CWD		
Sandra Stack	CWD		
Sami Sarrouth	Premier		

CITY OF CLEVELAND
DEPARTMENT OF PUBLIC UTILITIES/DIVISION OF WATER
 Crown, Kirtland, Nottingham, and Baldwin
 Wednesday, January 8, 2025
 9:00 a.m.

Traveling Screen Improvements Rebid

SIGN-IN SHEET

REPRESENTATIVE NAME (PLEASE PRINT)	COMPANY NAME (PLEASE PRINT)	TELEPHONE NUMBER	E-MAIL ADDRESS (PLEASE PRINT CLEARLY)
Wendy Bruzas	Cleveland Water	440-679-5654	wendy_bruzas@clevelandwater.com
Grace Rospert	Cleveland Water	216-664-2444	grace_rospert@clevelandwater.com
PAT CERVENIK	NERONE & SONS	216-662-2235	PAT@NERONE.BIZ
Renard A Nerone	Nerone & Sons	216-662-2235	Renard@Nerone.Biz
TOM ITRICONEC	BRAMHALL	216 402 7849	TOM@EKOPIAK-CONSTRUCTION.BIZ
Alfred Berelke	Bramhall	623-570-7870	MBR@BRAMHALL-ENGINEERING.COM
MIKE BRAMHALL	BRAMHALL ENGINEERING	440-343-4225	MBR@BRAMHALL-ENGINEERING.COM
JOEL FRAZIER	U/W MARFAC CONTE.	216 347 0083	JFRAZIER@DUUMARONE.COM
Cory Stewart	BissMuss, Inc.	419 779 3180	CSTEWERT@BISSMUSINC.COM
DEEVEE ALFILA	COLDHARBOR BID CO.	440-427-6180	DAlfilla@ColdHarbor.Biz
BOW COLEFFIS	COLDHARBOR BID CO.	216-346-4658	bco@coldharbor.us
Sami Samrouh	Premier Engineering	216-688-6462	Samrouh@PRMENG.COM
Scott Mabeur	CWD	216-664-3121	scott_mabeur@clevelandwater.com
ALMANSTED	VFP PUBLIC INC	440 231 9101	AL@VFPUBLICINC.COM