



City of Cleveland  
Justin M. Bibb, Mayor

Department of Finance  
Division of Purchases & Supplies  
601 Lakeside Avenue, Room 128  
Cleveland, Ohio 44114-1080  
216/664-2620 • Fax: 216/664-2177  
www.cleveland-oh.gov

January 30, 2025

## ADDENDUM No. 4

**BID TITLE: Reference: File No. 146-24 Traveling Screens Improvements  
Re-Bid**

**BID DUE:** Friday, February 7, 2025. Bid Must Be Delivered to the **Office of the Commissioner of Purchases and Supplies, Cleveland City Hall, 601 Lakeside Avenue, Room 128, Cleveland, Ohio 44114** before 12 o'clock Noon (Eastern Time).

**PLEASE NOTE THE FOLLOWING CLARIFICATIONS AND ADDITONS REPRESENT CHANGES THAT REPLACE AND SUPPLEMENT PREVIOUS INFORMATION SHOWN IN THE CONTRACT DOCUMENTS:**

### **Answer to Question Received:**

1. To apply the urethane coating to the guide angle, it would need to be fully encapsulated (100%). This can only be done by disassembling all components of the Traveling Screen, which is intended to be rehabilitated in place. To remove the guide angle, the screen itself must be taken out. Please confirm if this is the necessary approach, or clarify the extent of coating requested in the bid for the guide angle.

**Answer: CWD does not require encapsulation on all sides. We want the exposed steel prepped and painted. We do not want to disassemble the structural supports for painting. Caulk the gap at the interfaces between angle and structure and then spray as is. If it oversprays the concrete a little. It is ok.**

**No Further Questions Will Be Addressed.**

**Addendum #4 – File No. 146-24 Traveling Screens Improvements Re-Bid**



City of Cleveland  
Justin M. Bibb, Mayor

Department of Finance  
Division of Purchases & Supplies  
601 Lakeside Avenue, Room 128  
Cleveland, Ohio 44114-1080  
216/664-2620 • Fax: 216/664-2177  
www.cleveland-oh.gov

***THE BID OPENING DATE REMAINS  
FRIDAY, FEBRUARY 7, 2025  
at 12:00 NOON.***

**Attention Bidders:**

We have been requested to issue the enclosed Addendum to the above entitled bid project. This addendum is to advise all bidders of the following information:

Also, please acknowledge receipt of this addendum by faxing directly to my attention at (216) 664-2275.

\_\_\_\_\_  
Print & Sign Potential Bidder & Company Name

\_\_\_\_\_  
Today's Date

Also, please attach this addendum to the copy of the specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Thank you,

Jules Gilliam, Buyer  
Division of Purchases & Supplies

Cc: Commissioner Tiffany Johnson, Division of Purchases & Supplies

Attachments: Addendum #4 Cover Sheets – (Two) 2 Pages

Total: Two (2) Pages

**Addendum #4 – File No. 146-24 Traveling Screens Improvements Re-Bid**