



City of Cleveland
Justin M. Bibb, Mayor

Department of Finance
Division of Purchases & Supplies
601 Lakeside Avenue, Room 128
Cleveland, Ohio 44114-1080
216/664-2620 • Fax: 216/664-2177
www.cleveland-oh.gov

April 8, 2025

ADDENDUM 1

BID TITLE: File No. 46-25 Baldwin Filter Underdrains II

BID DUE: Thursday, April 17, 2025 at 12 o'clock noon (Eastern Time)

Attention Bidders:

We have been requested to issue the addendum for the following:

Please ensure that a copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

1. Answers to questions received.

If you have any questions regarding the attached, please contact Jules Gilliam at jgilliam@clevelandohio.gov. Thank you for your prompt attention and assistance in this matter.

Also, please ensure that copy of this addendum is included and returned with the bid specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Signature of Potential Bidder & Name of Company

Today's Date


Thank you,
Donia Patterson, Assistant Administrator
Purchases & Supplies
CC:

BALDWIN FILTER UNDERDRAINS II – FILE NO. 46-25

ADDENDUM NO. 1

Bid due date is April 17, 2025, and bids must be date stamped by 11:59 a.m. that day.

Answer to question received by the last day for questions:

1. Reference Sheet F-M-4, Section C. Upstream of the reinstalled venturi and downstream of the new mechanical seals a block is shown around the 24" pipe. Please provide a detail for the required block shown.

Answer: A thrust block is not required in this location. The box shown is an error in the CAD file plot to PDF.