



City of Cleveland
Frank G. Jackson, Mayor

Department of Finance
Division of Purchases & Supplies
601 Lakeside Avenue, Room 128
Cleveland, Ohio 44114-1080
216/664-2620 • Fax: 216/664-2177
www.cleveland-oh.gov

October 6, 2020

ADDENDUM NO. 1

BID TITLE: File no. 78-20 City of Parma Water Main Renewal Phase II

BID DUE: Thursday, October 22, 2020. 1201 Lakeside Avenue at 12:00 PM.

Attention Bidders:

We have been requested to issue the enclosed Addendum 1 to the above entitled bid project. This addendum is to advise all bidders of the following information:

1. Copy of pre-bid meeting sign-in sheet.
2. Last day for questions is Tuesday, October 13, 2020 by 12:00 P M.
3. Answer to question.

Bid due date shall remain Thursday, October 13, 2020. All bids must be sealed and time-stamped in our office on or before 11:59am.

Please acknowledge receipt of this addendum by emailing directly to my attention: jhutcheson@city.cleveland.oh.us and purchasing@city.cleveland.oh.us

Signature of Potential Bidder & Company Name

Today's Date

Also, please attach this addendum to the copy of the specifications furnished to you by this office, as it will have the same force and effect as if it were part of the specifications originally issued.

Thank you,

James Hutcheson, Buyer Division of Purchases & Supplies

Cc: Commissioner Tiffany Johnson/DPS
Buyer Asst. Royce Griffin/DPS

City of Parma Water Main Renewal Phase II – File No. 78-20

Addendum No. 1

The bid due date is October 22, 2020 by 11:59 a.m.

The last day for questions is October 13, 2020 by 12:00 p.m.

Attached is the sign-in sheet from the pre-bid meeting held on October 1, 2020.

Answer to question from the pre-bid meeting:

1. If we cross a lead line on the existing main that is damaged during construction do we have to replace it immediately?

Answer: The City of Parma Water Main Renewal Phase II project is not employing bypass for the length of the project. The existing main will remain in service until the new main is in place; therefore, when an existing lead line that is connected to an existing main is damaged during construction the contractor is to put the customer on a temporary bypass until the new copper line can be connected to the new main. Partial repairs are not allowed.

Note that if lead is discovered on both the customer side and the city side, both connections must be replaced with new copper before the customer can be connected to the new main.

CITY OF CLEVELAND
DEPARTMENT OF PUBLIC UTILITIES
NON-MANDATORY PRE-BID MEETING
 Thursday, October 01, 2020
 10:00 a.m.

CITY OF PARMA WATER MAIN RENEWAL PHASE II

SIGN-IN SHEET

	REPRESENTATIVE NAME (PLEASE PRINT)	COMPANY NAME (PLEASE PRINT)	TELEPHONE NUMBER	E-MAIL ADDRESS (PLEASE PRINT CLEARLY)
1	Colin Gower	The Vallejo Company		colin@vallejo.com
2	Mark Adzema	Terrace Construction		mtadzema@terraceconstruction.com
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				